



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Classical Academy Charter School
 1255 Main Ave.
 Clifton, NJ 07011

APL Order ID Number: 2030075
 Collected : 02/26/2022 6:48
 Received: 03/01/2022

Contact:
 Client Project: Classical Academy Charter School

Contact: 03/18/2022 15:33
 Customer Service Rep: Tony Tudra

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030075-01	Drinking Water	Girls Bathroom Sink 1						
Total Metals								
Copper	EPA 200.8	3/18/22 13:16	3/18/22 13:16	< 0.00200	U		0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:16	3/18/22 13:16	< 0.00200	U		0.00200	mg/L
2030075-02	Drinking Water	Boys Bathroom Sink 2						
Total Metals								
Copper	EPA 200.8	3/18/22 13:19	3/18/22 13:19	0.0838			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:19	3/18/22 13:19	< 0.00200	U		0.00200	mg/L
2030075-04	Drinking Water	Cafe 1 Tub Cleaning Sink 4						
Total Metals								
Copper	EPA 200.8	3/18/22 13:38	3/18/22 13:38	0.0170			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:38	3/18/22 13:38	< 0.00200	U		0.00200	mg/L
2030075-05	Drinking Water	Staff Bathroom Sink 5						
Total Metals								
Copper	EPA 200.8	3/18/22 13:40	3/18/22 13:40	0.0620			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:40	3/18/22 13:40	< 0.00200	U		0.00200	mg/L
2030075-06	Drinking Water	Nurse Sink 6						
Total Metals								
Copper	EPA 200.8	3/18/22 13:43	3/18/22 13:43	0.00640			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:43	3/18/22 13:43	< 0.00200	U		0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030075-07 Drinking Water SBA Sink 7								
Total Metals								
Copper	EPA 200.8	3/18/22 13:45	3/18/22 13:45	0.0146			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:45	3/18/22 13:45	0.00225			0.00200	mg/L
2030075-08 Drinking Water Gym Sink 8								
Total Metals								
Copper	EPA 200.8	3/18/22 13:48	3/18/22 13:48	0.0912			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:48	3/18/22 13:48	< 0.00200	U		0.00200	mg/L
2030075-09 Drinking Water Water Cooler 9								
Total Metals								
Copper	EPA 200.8	3/18/22 13:50	3/18/22 13:50	0.00417			0.00200	mg/L
Lead	EPA 200.8	3/18/22 13:50	3/18/22 13:50	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns
 H - Indicates a Hold Time violation
 D1 - Sample was Decanted (Dissolved)

Brian Wood
 Laboratory Director

